

# MINI VERSA TRIM

- Small, narrow glow light
- Available in warm white, natural white, cool white, red, green, and blue
- UL Listed
- IP66 rated
- Operating temperature: -20 to 45°C
- Operating voltage 11V – 14Vdc
- UV Compliant with ISO 4892-3
- Salt spray compliant with ISO 9227




## SPECIFICATIONS

PART NUMBER	LED COLOR	COLOR TEMP/ WAVELENGTH	LUMENS/Ft.	CURRENT/Ft.	MAX RUN LENGTH
461349	Warm White	3000 K	67.0 lm	0.208 A	24 Ft
462349	Red	630 nm	23.0 lm	0.208 A	24 Ft
464349	Daylight White	4000 K	58.1 lm	0.208 A	24 Ft
465349	Green	520 nm	73.7 lm	0.208 A	24 Ft
466349	Blue	465 nm	16.2 lm	0.208 A	24 Ft
468349	Cool White	5000 K	59.9 lm	0.208 A	24 Ft


*Vista reserves the right to modify this specification without prior notice.*

# DIMENSIONS


## SIDE VIEW



## LIGHT STRIP LOOKING AT LENS



## LIGHT STRIP CROSS SECTION





Vista reserves the right to modify this specification without prior notice.

**BUILD NOTES:**

1. MAXIMUM RUN LENGTH FOR ANY ASSEMBLY IS 360 SETS (295 1/4").

2. WIRE LEAD DIRECTION MUST BE DEFINED WHEN THE PRODUCT IS SHIPPED ASSEMBLED WITH ADHESIVE. LEAD OUT LEFT END (LOLE) AND LEAD OUT RIGHT END ARE DEFINED BY THE DIRECTION THE LEAD COMES OUT OF THE CHANNEL WHILE THE ADHESIVE IS FACING AWAY FROM THE INSTALLER AND THE LIGHT IS FACING TOWARDS THE INSTALLER.



————— *Vista reserves the right to modify this specification without prior notice.* —————

---

# INSTALLATION INSTRUCTIONS

**PRODUCT IDENTIFICATION:** Determine the mount type of your linear light

- Adhesive – Full length or intermittent adhesive attached to the bottom of the extrusion profile.
- Channel – Full length rigid or semi-rigid channel, mounted with fasteners, available with adhesive backing for temporary hold. Some channel products come with finishing tips which contain a fastener location or pre-drilled support holes inside of the channel for fasteners. Other channels must be pre-drilled prior to fastening to the mount surface.

**PREPARATION:** Prepare the mount surface in accordance with your fastener type

- Adhesive – It is recommended to use an adhesive promoter in order to increase the bond strength for all types of adhesive tape (adhesive promoter not included). If an adhesive promoter is not available, prep the mount surface with isopropyl alcohol to increase bond strength. Make sure that while mounting flexible lights, a bend radius smaller than the minimum bend radius of your selected product is not applied. Mounting flexible lights beyond the minimum bend radius will void warranty.
- Channel – If the channel has an adhesive backing follow the preparation instructions for adhesives above. If the channel has finishing tips, make sure that the full assembly will fit in the intended mounting location. Channels should be mounted on a flat surface to ensure that light extrusions will remain secure. If holes are not already pre-drilled into the channel, locate and drill the mounting holes now. It is recommended to have a mount hole at least every 9”.

**FASTENING:** Using product appropriate fasteners, mount the light to your desired surface. It is up to the installer to ensure the proper fasteners are used for the application mount surface. Mechanical fasteners supplied by Vista are generic fasteners. If these are not appropriate for the intended mount surface, a customer supplied fastener should be identified and used.

- Adhesive only – After preparation, peel away the adhesive backer. It is recommended for long, non-linear applications, that the adhesive backer is removed in sections so that the light can be routed without accidental adhesion. After initial adhesion, apply pressure evenly throughout the adhered surface for at least 30 seconds. All adhesive mounted products should be allowed 24 hours of cure time before being acted upon by an outside force to ensure best adhesion.
- Channel – Remove the light extrusion from the channel if already assembled. If the channel selected has adhesive, determine the required mounting position of the light and peel away the adhesive backer. Apply the channel to the mount location and apply pressure evenly throughout the adhered surface for at least 30 seconds. This is intended to be a temporary adhesion. Apply fasteners into the pre-drilled holes inside of the channel for permanent fixturing. The holes located nearest each end of the channel are meant for wire routing and finishing tips see **Figure 1**. Do not apply fasteners to these holes. Drill a hole through the mounting surface in the proper location for wire routing if necessary. Make sure that if there are finishing tips and the wires are routed straight out of the end of the extrusion, the wire routing hole will not interfere with the screw mounting of the finishing tip. Press or slide the light extrusion into the channel, Apply finishing tips to channel (if applicable) routing wires through if necessary.



**Figure 1:** Wire routing and finishing tip holes. Do not apply fasteners

**WIRING:** Route wires as necessary for the application. Do not pinch or puncture wires with fasteners. Do not route wires around sharp edges. A wire loom should be used for protection if wires are to be routed through areas where they may encounter sharp edges, in an application that would experience high amounts of vibration, in areas that may have fasteners protruding into them during later assembly, or other extreme conditions. Standard wiring outputs can be seen below.

- **Single Color Lights**



Black Wire (Ground)  
Red Wire (Power)

---

*Vista reserves the right to modify this specification without prior notice.*

---

**DISCONNECT POWER SOURCE (BATTERY) BEFORE STARTING ELECTRICAL WORK.**

Recommended methods for splicing wires together (*parts not included in Vista product kits*):

- Solder and cover bare wires with heat shrink or electrical tape.
- Insulation-displacement connector (IDC) / insulation-piercing contact (IPC).
- Twist on wire connector, “wire nut”.
- Crimp connector, “Butt splice”.

**WARNING:**

1. Supply current and wattage must not exceed the rated values on the specification documents.
2. Incorrect polarity or improper wiring may cause personal injury and/or damage to the product. It is recommended that an electrical technician, professional, or similarly qualified individual finish wiring.
3. To avoid electrical shock risk, all failures should be examined by a qualified technician.
4. Environmental suitability, including but not limited to water resistance, varies based on product design. Unless explicitly noted, products are to be installed in a location shielded from outdoor elements. To avoid irreparable damage, refer to specification sheets to locate products in a proper environment.
5. Do not install products near an open flame or in high temperature environments unless the product is explicitly designed to function as such. Adversely, do not install products in excessively cold environments unless explicitly designed to function as such. Refer to product spec sheets/drawings for information about minimum and maximum operating temperatures.
6. Vista Manufacturing Inc. is not liable for any injuries or damage caused due to improper wiring or installation.

---

*Vista reserves the right to modify this specification without prior notice.*

---